



October 31, 2024

Sunriver Water Customers,

This year water systems nationwide were required to conduct a random statistical survey of water distribution systems to comply with the 2021 Revised Lead and Copper Rule. This survey consisted of a physical inspection of both Sunriver Water and the customers service line. The inspection consisted of digging down to visually document with pictures the pipe materials used to supply water to the residence and or business.

The state required number of inspections found no unknown pipe materials or lead lines used to supply water to the public.

Sunriver Water complies with all regulatory requirements set forth by federal, state and local authorities.

Steve C. Yeoman
Water Manager
Sunriver Water LLC